



## WARWICK SEWER AUTHORITY INDUSTRIAL PRETREATMENT PROGRAM TOXIC AND CONVENTIONAL POLLUTANT DISCHARGE LIMITS (LOCAL LIMITS)

Pollutant	Approved Daily Maximum Limit (mg/l)	Approved Surcharge Limit (mg/l)	Approved Surcharge Rate (per lb)	Proposed Surcharge Rate <sup>a</sup> (per lb)
Arsenic	0.10			
Beryllium	0.003			
Cadmium	0.05			
Chromium	2.77			
Copper	0.70			
Cyanide	0.16			
Lead	0.15			
Mercury	0.001			
Nickel	3.98			
Selenium	0.20			
Silver	0.32			
Zinc	1.00			
Total Toxic Organics	2.13			
CBOD	2,500	250	\$0.30	\$0.45
TSS	1,000	250	\$0.30	\$0.37
O & G (vegetable)	300	100	\$0.24	\$0.71
O & G (petroleum)	25			
pH Range	6.0 – 10.0 s.u.			
Ammonia	b	35		\$2.38
Total Phosphorus	b	8		\$6.05
Total Nitrogen	b	b		b

<sup>a</sup>2016 User Rate Evaluation by ARCADIS, anticipated effective date January 1, 2019

<sup>b</sup>Maximum Daily Limits, Surcharge Limits and Rates will be developed for future application as warranted.