


**TYPICAL CROSS SECTION**

**NOTES:**

1. PRECAST DROPS MAY BE CONSIDERED AN ACCEPTABLE ALTERNATE TO CAST IN PLACE, HOWEVER THE CONTRACTOR SHALL SUBMIT DETAILED SHOP DRAWINGS OF THE DROP UNITS FOR REVIEW AND APPROVAL BY THE ENGINEER AND OWNER PRIOR TO CONSTRUCTION.
2. AS A MINIMUM, FILTER FABRIC SHALL BE PLACED ON THE TOP OF THE BEDDING. PLACEMENT OF FILTER FABRIC ON THE TOP, BOTTOM AND SIDES OF THE BEDDING WILL BE DETERMINED ON A SITE SPECIFIC BASIS BY THE ENGINEER.

Detail No. WSA - 20 Chimney Details for Service Connections (10' Depth or Greater)	
<b>Contract BB</b>	
Date: September 2011	Scale: Not to Scale
	<b>WARWICK SEWER AUTHORITY</b> 125 Arthur Devine Boulevard Warwick, Rhode Island 02889