


NOTE:
 COVER SHALL BE CAST IRON, LOCKING LID MARKED SEWER
 AND DESIGNED FOR H-20 TRAFFIC LOADING.

Detail No. WSA - 21 Service Cleanout	
Contract BB	
Date: September 2011	Scale: Not to Scale
	WARWICK SEWER AUTHORITY 125 Arthur Devine Boulevard Warwick, Rhode Island 02889