



TEMPORARY PLUG END OF SERVICE. REMOVE WHEN CONNECTING TO EXISTING HOUSE SERVICE.

FINISH GRADE

COVER

HOUSE SERVICE CONNECTION MARKER (SEE DETAIL)

4' MIN. COVER OR DEPTH AS DIRECTED IN FIELD. MUST SERVE BASEMENT UNLESS OTHERWISE APPROVED.

CURB BOX

PROVIDE 2x4 OR 2x3 BRACE FOR LOCATING AND TESTING

FILTER FABRIC

END PLUG

CRUSHED STONE

LPSS MAIN (SIZE VARIES)

6" MIN.

SADDLE TAP

MATERIAL UNDISTURBED

CURB STOP

ONE WAY CHECK VALVE

EXTEND CRUSHED STONE BED 2' BEYOND END PLUG

**NOTES:**

1. COVER SHALL BE CAST IRON, LOCKING LID MARKED SEWER AND DESIGNED FOR H-20 TRAFFIC LOADING.
2. AS A MINIMUM, FILTER FABRIC SHALL BE PLACED ON THE TOP OF THE BEDDING. PLACEMENT OF FILTER FABRIC ON THE TOP, BOTTOM AND SIDES OF THE BEDDING WILL BE DETERMINED ON A SITE SPECIFIC BASIS BY THE ENGINEER.

Detail No. WSA - 22  
Typical LPSS Service Connection

Contract BB

Date: September 2011

Scale: Not to Scale



**WARWICK SEWER AUTHORITY**

125 Arthur Devine Boulevard  
Warwick, Rhode Island 02889