

GREASE TRAP CAPACITY

KITCHEN FLOW	PRIMARY TANK MINIMUM CAPACITY	SECONDARY TANK MINIMUM CAPACITY
LESS THAN 2,000 GAL	1,500 GAL	1,000 GAL
2,000 GAL – 2,999 GAL	2,000 GAL	1,500 GAL
3,000 GAL – 3,999 GAL	3,000 GAL	2,000 GAL
4,000 GAL – 4,999 GAL	4,000 GAL	2,000 GAL
5,000 GAL – 5,999 GAL	5,000 GAL	3,000 GAL
6,000 GAL – 6,999 GAL	6,000 GAL	3,000 GAL
7,000 GAL – 7,999 GAL	7,000 GAL	4,000 GAL
8,000 GAL – 8,999 GAL	8,000 GAL	4,000 GAL
9,000 GAL – 9,999 GAL	9,000 GAL	5,000 GAL

NOTES:

1. SUBJECT TO WSA APPROVAL, A SINGLE UNIT MAY BE UTILIZED IF THE TOTAL CAPACITY EQUALS OR EXCEEDS THE COMBINED CAPACITY OF THE PRIMARY AND SECONDARY TASKS.
2. ALL JOINTS MUST BE SEALED WITH BUTYL RUBBER GASKETS.
3. GREASE TRAP SELECTION IS SUBJECT TO CONFORMANCE WITH LOCAL AND STATE BUILDING CODES. WSA-26 IS PROVIDED AS A REFERENCE BUT CONTRACTOR MUST CONFIRM CONFORMANCE TO THE BUILDING CODES.

Detail No. WSA - 26 (2 of 2)
Grease Trap

Contract BB

Date: September 2011

Scale: Not to Scale



WARWICK SEWER AUTHORITY

125 Arthur Devine Boulevard
Warwick, Rhode Island 02889