


		ANCHORAGES				
BEND		PIPE SIZE-D (DIA.)				
		6"	8"	12"	16"	20"
1/8	R	2'-6"	3'-0"	4'-6"	5'-4"	6'-0"
	S	2'-6"	2'-9"	3'-6"	2'-6"	5'-6"
	T	3'-0"	4'-0"	4'-9"	7'-0"	9'-6"
1/16	R	2'-0"	2'-8"	4'-0"	4'-6"	5'-0"
	S	1'-9"	2'-3"	2'-6"	3'-2"	3'-8"
	T	2'-6"	3'-4"	4'-0"	6'-0"	8'-6"
1/32	R	1'-6"	2'-0"	3'-0"	3'-8"	4'-3"
	S	1'-3"	1'-9"	2'-0"	2'-4"	2'-6"
	T	2'-0"	2'-6"	3'-0"	4'-6"	5'-9"

- NOTES:**
1. ALL CONCRETE SHALL BE 3000 PSI @ 28 DAYS.
 2. CONCRETE THRUST BLOCKS SHALL BEAR AGAINST UNDISTURBED EARTH.
 3. ALL FORCE MAIN BENDS, TEES, MAIN TAPS, AND END CAPS SHALL REQUIRE A CONCRETE THRUST BLOCK.
 4. THE DIMENSIONS PROVIDED REPRESENT THE MINIMUM REQUIREMENTS. THE ACTUAL ANCHOR BLOCK DIMENSIONS WILL BE BASED UPON THE SITE CONDITIONS AND SYSTEM PRESSURE ON A PROJECT SPECIFIC BASIS.

Detail No. WSA - 30 Anchor Block Details	
Contract BB	
Date: September 2011	Scale: Not to Scale
	WARWICK SEWER AUTHORITY 125 Arthur Devine Boulevard Warwick, Rhode Island 02889