


INSTALL AT CENTER OF EACH GRAVITY MANHOLE REACH.

NOTES:

1. HEIGHT OF CLAY DAM SHALL ONLY VARY UPON COMPLETION OF SOIL AND ENGINEERING ASSESSMENT.
2. NO FITTING SHALL BE LOCATED WITHIN 4' OF DAM.
3. LOCATION, HEIGHT AND WIDTH OF DAM SHALL BE DETERMINED BY ENGINEER ON A SITE SPECIFIC BASIS.

Detail No. WSA - 33 Typical Trench Dam	
Contract BB	
Date: September 2011	Scale: Not to Scale
	WARWICK SEWER AUTHORITY 125 Arthur Devine Boulevard Warwick, Rhode Island 02889